UL Product iQ™

HLXS.EX26746 - Butterfly Valves

Butterfly Valves

See General Information for Butterfly Valves

HACI AYVAZ ENDUSTRIYEL MAMULLER SAN VE TIC A.S. EX26746
Hadimkoy Mahallesi
Mustafa Inan Caddesi No:44 Arvavutkoy
34555 istanbul, TURKEY

Model	Size, NPS	Body Type	Pressure Rating, psig (Bar)	Indicator Post	Supervisory Switch*
Butterfly valve					
ABV-G300	2, 2.5, 2.5 (76.1 mm), 3, 4, 5, 5 (139.7 mm), 6, 6 (165.1 mm), 8, 10, 12	Groove	300	—	I/O
ABV-W300	2, 2.5, 3, 4, 5, 6, 8	Wafer	300		
ABV-W250	2, 2.5, 3, 4, 5, 6, 8, 10, 12		250		
ABV-L300	2, 2.5, 3, 4, 5, 6, 8	Lug	300		
ABV-L250	2, 2.5, 3, 4, 5, 6, 8, 10, 12		250		
ABV-300T	1, 1-1/4, 1-1/2, 2, 2-1/2	Threaded	300	—	I, O
ABV-300G	1-1/4, 1-1/2, 2, 2-1/2	Grooved	300	—	I, O
ABV-G400	2.5 (76.1 mm), 2.5, 3, 4, 5, 5 (139.7 mm), 6, 6 (165.1 mm), 8, 8 (216.3 mm), 10, 10 (267.4 mm), 12, 12 (318.4 mm)	Groove	300	—	I, O
ABV-W400	2.5, 3, 4, 5, 6, 8, 10, 12	Wafer	300	—	I, O
ABV-175T	1, 1-1/4, 1-1/2, 2	Lug	175	—	I/O

Note: The shaft material designation for groove end configuration is SS431, for wafer or lug end configuration is SS420.

Models ABV-G300, ABV-W300, ABV-W250, ABV-L300, ABV-L250, with gear box with micro-switches inside.

Model name end with "-300/250" means connect with flange comply with ASME B16.5, class 150; Wafer butterfly valves are of universal flange standard design; Lug butterfly valves can accommodate the different flange standards by modification on the drilling.

* I = Indoor installation; O = Outdoor installation

Last Updated on 2018-04-10

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"