

HMER.EX27112 - Check Valves

Check Valves

[See General Information for Check Valves](#)**HACI AYVAZ ENDUSTRIYEL MAMULLER SAN VE TIC A.S.**

EX27112

Hadimkoy Mahallesi
Mustafa Inan Caddesi No:44 Arvavutkoy
34555 istanbul, TURKEY

Model	Type	Valve Seat Facing	Nom Pipe Size, NPS	End Config	Rated Pressure, psig	Installation Position
AWCV-300	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	300	H, V
AWCV-250	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	250	H, V
AWCV-200	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	200	H, V
AWCV-PN16	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	233	H, V
AWCV-PN10	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	175	H, V
AFCV-200	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	200	H, V
AFCV-PN16	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
AFCV-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
AGCV-200	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	200	H, V
AGCV-250	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	250	H, V
AGCV-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	300	H, V
AGCV-PN10	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	175	H, V
AGCV-PN16	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	233	H, V

End Configuration:

F - Flanged

W - Wafer

G - Grooved

Installation Position:

H - Horizontal installation

V - Vertical installation

Last Updated on 2019-07-11

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"