

Sprinkler System Alarm Testers

Each separate sprinkler system must be equipped with a separate waterflow alarm. In a high rise building, the system for each floor must be separately alarmed. Where pressure reducing valves are used, a dual alarm and drain piping arrangement is required. The alarm testers listed below combine test and drain valves, a waterflow sight glass, and a calibrated flow orifice in a single assembly to simplify the piping required for such arrangements.

Model STDV, GTDV

Product Specification

| Model No | Nominal Pipe Size | | K-Factor | Rated Working Pressure | | Remarks |
|----------|-------------------|------|----------------------|------------------------|--------|---------|
| | in | (mm) | | psi | (kPa) | |
| STDV | 1 | (25) | 4.2, 5.6 | 300 | (2065) | a |
| STDV | 1 1/4 | (32) | 4.2, 5.6 | 300 | (2065) | a |
| STDV | 1 1/2 | (40) | 4.2, 5.6, 14.0, 25.2 | 300 | (2065) | a |
| STDV | 2 | (50) | 4.2, 5.6, 14.0, 25.2 | 300 | (2065) | a |
| GTDV | 1 1/4 | (32) | 4.2, 5.6 | 300 | (2065) | b |
| GTDV | 1 1/2 | (40) | 4.2, 5.6, 14.0, 25.2 | 300 | (2065) | b |
| GTDV | 2 | (50) | 4.2, 5.6, 14.0, 25.2 | 300 | (2065) | b |

Remarks:

- a. Devices supplied with female NPT threaded end connections.
 b. Devices supplied with grooved end connections.

| | |
|-------------------------------------|--|
| Company Name: | Haci Ayvaz Endüstriyel Mamülleri San. ve Tic. A.S. |
| Company Address: | Atatürk Sanayi Bölgesi Mustafa Inan Cad. No: 44, 34555 Hadimköy-Istanbul, Turkey |
| Company Website: | http://www.ayvaz.com |
| New/Updated Product Listing: | No |
| Listing Country: | Turkey |
| Certification Type: | FM Approved |
| Class of Work: | 1625-Branch Line Testers |