



USQT.S36377 - Extinguishing System Attachments

Extinguishing System Attachments

[See General Information for Extinguishing System Attachments](#)

HACI AYVAZ ENDUSTRIYEL MAMULLER SAN VE TIC A.S.

S36377

Hadimkoy Mahallesi
Mustafa Inan Caddesi No:44 Arvavutkoy
34555 istanbul, TURKEY

Supervisory switches, Model NRS-SS and OSY-SS

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet Pipe, Paddle Type

Model	Size, in.	Pipe Schedule	Max System Pressure, kPa
AWFD	2.0	10 through 40	365
	2.5	10 through 40	365
	3.0	10 through 40	365
	4.0	10 through 40	365
	5.0	10 through 40	365
	6.0	10 through 40	365
	8.0	10 through 40	365

Last Updated on 2020-07-10

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"